



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Sacre Coeur

172 Burke Rd Glen Iris

Contract No: P3316

Maintenance ID:

Date of Call: 16-10-2018

Time of Arrival: 10:55:00

Time of Departure: 12:30:00

Maintenance Details

Maintenance Description: Regular service \r\nLook at thumping sound from lift 1, adjusted lock on lv1 as it was snatching causing sound.\r\n

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	Y
Test all car safties	Y	Y
Clean & Check all M/R Equipment	Y	Y
Clean out controller ad check operation of various parts.	Y	Y
Check tuning ajustments	Y	Y
Check car door operator and associated equipment.	Y	Y
Clean & check landing door equipment	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y
Check pit equipment and check water for pit	Y	Y
Safety gear full performance test	Y	Y
Test Emergency Light Unit	Y	Y
Test Lift Communications	Y	Y

Service Technician

Zane Tregurtha

Customer Email

mark.toy@sac.vic.edu.au