



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Tarneit Railway

0 Cnr Leakes Rd & Derrumitt Rd Tarneit

Contract No: 3610

Maintenance:

Date of Call: 06-12-2018

Time of Arrival: 12:30:00

Time of Departure: 14:30:00

Maintenance Details

Maintenance Description: Routine service \r\nElu test pass\r\nLift 2 not sealed theres birds flying around in lift shaft\r\nReported for months now and still nothing done. Re raised issue with station staff

Maintenance Task	1	2
Contact Building Rep. Check Ride & Appointments.	Y	
Test all car safties	Y	
Clean out controller ad check operation of various parts.	Y	
Check car door operator and associated equipment.	Y	
Clean & check landing door equipment	Y	
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	
Check and ajust car & cwt guide shoes	Y	
check brake operation rope brake and assocated equipment	Y	
Check pit equipment and check water for pit	Y	
Report any major rapirs	Y	
Test Emergency Light Unit	Y	
Test Lift Communications	Y	

Service Technician

Matt Grieger

Customer Email

geoff.young@vline.com.au