



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Dart Street 2-8
2-8 Dart Street Highett
Contract No: W3697

Callouts: 22562

Date of Call: 11-12-2018 11:55:45
Time of Arrival: 11-12-2018 12:10:00
Rectification Time: 11-12-2018 13:13:00
Time of Departure: 11-12-2018 13:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Not Stopping Level

For Lift(s): 1

For Floor(s): B

Call Description: lift is not leveling with floors

Order Number: w/o1012188634

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found lift not stopping level, perform new shaft teach and adjust levels. Test operation - ok.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

.