



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Elgin Street 20, Carlton
20 Elgin Street Carlton
Contract No: P3117

Callouts:

Date of Call: 12-11-2018 19:00:00
Time of Arrival: 12-11-2018 19:40:00
Rectification Time: 12-11-2018 20:00:00
Time of Departure: 12-11-2018 20:37:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 1

For Floor(s): 9

Call Description: Doors open

Order Number: 15551

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): Reset Door Operator

Work Description: Cleaned and lubed up pivot point on the door operator/vains. Performed a new learn run

Part Required: No Parts Required

Service Technician

Steven Johnson

Report Customer

1