



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Ormond St 94, Kensington
94 Ormond St Kensington
Contract No: P3421

Maintenance:

Date of Call: 27-11-2018
Time of Arrival: 12:30:00
Time of Departure: 13:30:00

Maintenance Details

Maintenance Description: Routine maintenance. Water in both lift pits. Inform bldg mgmt.

| Maintenance Task | 1 | 2 |
|---|---|---|
| Contact Building Rep. Check Ride & Appointments. | Y | Y |
| Clean & Check all M/R Equipment | Y | Y |
| Clean out controller ad check operation of various parts. | Y | Y |
| Check tuning adjustments | Y | Y |
| Check car door operator and associated equipment. | Y | Y |
| Check pit equipment and check water for pit | Y | Y |
| Test Lift Communications | Y | Y |

Service Technician

mat tehan

Customer Email