



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

King St 27, Melbourne
27 King St Melbourne
Contract No: P3304

Callouts: 22510

Date of Call: 07-12-2018 11:37:00
Time of Arrival: 07-12-2018 11:50:00
Rectification Time: 07-12-2018 12:50:00
Time of Departure: 07-12-2018 12:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 5

Call Description: Lift is not working. \r\nReported by: Jonathon (?) 0413 394 422

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: lift out of order on level 5 found obstruction in car door tracks removed rubbish checked door operation ok,\r\nfound landing call button panel the ground level 5 reinstalled checked operation ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

John