

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Alfred St 33, North Melbourne
33 Alfred St North Melbourne
Contract No: P3430

Callouts ID: 22080

Date of Call: 23-10-2018 15:35:07 Time of Arrival: 23-10-2018 15:50:00 Rectification Time: 24-10-2018 16:10:00 Time of Departure: 24-10-2018 16:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 2

Call Description: out of order with the doors closed

Order Number: 15276

DESCRIPTION OF WORK

Fault Found (CAUSE): Govenor Tripped

Work Action (CORRECTION): See Work description

Work Description: RB tripped. Check clearances on lv 2 and 3. Run lift and monitor.

Part Required: No Parts Required

Service Technician Report Customer

mat tehan