



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Derby St 56, Kensington
56 Derby St Kensington
Contract No: P3419

Callouts:

Date of Call: 23-11-2018 0:39:00
Time of Arrival: 23-11-2018 1:15:00
Rectification Time: 23-11-2018 2:00:00
Time of Departure: 23-11-2018 2:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 7

Call Description: O.o.o

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Adjust door activation arm.

Part Required: No Parts Required

Service Technician

mat tehan

Report Customer

.