



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Crossley Hotel
51 Lt Bourke St Melbourne
Contract No: P3532

Callouts: 22782

Date of Call: 04-01-2019 16:25:56
Time of Arrival: 04-01-2019 17:00:00
Rectification Time: 04-01-2019 17:30:00
Time of Departure: 04-01-2019 17:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 5

Call Description: out of order - may be on level 5

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): See Work description

Work Description: Car doors relaxed on landing lock rollers\r\nCar door motor extremely hot\r\nSuspect motor overheated\r\nShut down overnight to allow motor cool down

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer

Shelly 96391639