



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Barkly St 250, Footscray
250 Barkly St Footscray
Contract No: P3309

Callouts ID: 21992

Date of Call: 15-10-2018 13:02:30
Time of Arrival: 15-10-2018 13:25:00
Rectification Time: 15-10-2018 13:50:00
Time of Departure: 15-10-2018 14:25:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): c6

Call Description: 4 people stuck in lift

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: No passengers stuck on arrival\r\nLast error logged was door open time exceeded but suspected result of opening doors manually if was stuck\r\nCheck car doors and c6 doors \r\nTest operation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer

0478 733 142