



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Ginifer station
0 St Albans Road Ginifer
Contract No: P3639

Callouts: 22367

Date of Call: 22-11-2018 13:09:44
Time of Arrival: 22-11-2018 14:30:00
Rectification Time: 22-11-2018 14:30:00
Time of Departure: 22-11-2018 15:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 1

For Floor(s):

Call Description: Phone is not working, comms have attended this is lift maintainer issue

Order Number: 659407

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Swapped working lx8 unit from lift 2 on to lift 1 same issue occur\r\nProven not lx8 unit or our equipment\r\nPhone line active but no dial to suspect fault with phone line\r\nNotified sean kerr

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer