



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Wesley College (557 St Kilda Rd, St Kilda)
557 St Kilda Rd St Kilda
Contract No: P3287

Callouts:

Date of Call: 26-11-2018 8:40:00
Time of Arrival: 26-11-2018 8:55:00
Rectification Time: 26-11-2018 9:30:00
Time of Departure: 26-11-2018 9:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 3

For Floor(s): g

Call Description: Lift o.o.o middle school

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): Drive Lift Back Through Limit

Work Description: Lift through bottom limit due to sensor moving. adjusted sensor and drove lift back through limit ran and tested

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

.