



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Metro Laverton

Metro Laverton Station Laverton

Contract No: P3587

Maintenance:

Date of Call: 27-11-2018

Time of Arrival: 12:00:00

Time of Departure: 14:00:00

Maintenance Details

Maintenance Description: Routine service\r\nReplace 1 faulty tube lift 3\r\nRun count 3-378117 4-1140438

Maintenance Task	Lift 1	Lift 2	Lift 3	Lift 4
Contact Building Rep. Check Ride & Appointments.	Y	Y	Y	Y
Test all car safties	Y	Y	Y	Y
Clean out controller ad check operation of various parts.	Y	Y	Y	Y
Check car door operator and associated equipment.	Y	Y	Y	Y
Clean & check landing door equipment	Y	Y	Y	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y	Y	Y	Y
Check and ajust car & cwt guide shoes	Y	Y	Y	Y
Check all safety switches, limits in lift well	Y	Y	Y	Y
Check pit equipment and check water for pit	Y	Y	Y	Y
Report any major rapirs	Y	Y	Y	Y
Test Lift Communications	Y	Y	Y	Y

Service Technician

Matt Grieger

Customer Email