



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel
131 King St Melbourne
Contract No: P3249

Callouts ID:

Date of Call: 20-10-2018 8:45:00
Time of Arrival: 20-10-2018 9:10:00
Rectification Time: 20-10-2018 9:31:00
Time of Departure: 20-10-2018 9:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 1

Call Description: Lift ooo on level 1

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift 2 ooo, found sm01 board wasn't getting any outputs, found 24v was low on the power supply, increased voltage and tested operation of lift

Part Required: No Parts Required

Service Technician

Dwain Sanderson

Report Customer

reception