



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Glenhuntly Rd 242, Elsternwick
242 Glenhuntly Rd Elsternwick
Contract No: P3449

Callouts:

Date of Call: 16-11-2018 19:29:00
Time of Arrival: 16-11-2018 23:45:00
Rectification Time: 17-11-2018 0:35:00
Time of Departure: 17-11-2018 0:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): basement

Call Description: lift 2 stuck in basement

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lift 50mm below bottom floor timed out\r\ndrove up checked releve circuit\r\nchecked switch and magnets on top of car\r\nretested releve circuit,\r\nlift levelling up ok.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

costa