



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Civic Centre City of Whittlesea
25 Ferres Blvd South Morang
Contract No: S3042

Maintenance:

Date of Call: 30-12-2018
Time of Arrival: 11:34:00
Time of Departure: 12:34:00

Maintenance Details

Maintenance Description: Lift pit has had water ingress in pit and contaminated oil. Please remove water from pit.

Maintenance Task	Civic Centre
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check tuning ajustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check all safety switches, limits in lift well	Y
check brake operation rope brake and associated equipment	Y
Check pit equipment and check water for pit	Y
Clean lift well equipment	Y
Check trailer flexes, attachments running clearance	Y
Check hydrolic tank oil level, valves RAM etc	Y

Service Technician

Marek Torrico

Customer Email

kana.kanakeswaran@whittlesea.vic.gov.au