



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Victoria Hotel
215 Lt Collins St Melbourne
Contract No: P3234

Callouts:

Date of Call: 03-12-2018 18:58:00
Time of Arrival: 03-12-2018 19:30:00
Rectification Time: 03-12-2018 20:10:00
Time of Departure: 03-12-2018 20:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 4

For Floor(s): 1

Call Description: reported lift button on level 1 not lighting up.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: lift 4 stuck on level 1 door operator fault error 30, down button not calling other lifts, reset car door operator checked operation returned lift to service.

Part Required: No Parts Required

Service Technician

Robert Pelle

Report Customer

Nick