



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Lonsdale St 103, Melbourne
103 Lonsdale St Melbourne
Contract No: P3290

Callouts: 22355

Date of Call: 20-11-2018 15:19:17
Time of Arrival: 20-11-2018 15:40:00
Rectification Time: 20-11-2018 16:15:00
Time of Departure: 20-11-2018 16:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Noisy

For Lift(s): 1

For Floor(s): g

Call Description: lift is making rubbing noise

Order Number: x

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Faulty counterweight bearing lift shutdown

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

-