



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Waltham St 9, Sandringham
9 Waltham St Sandringham
Contract No: P3260

Maintenance:

Date of Call: 13-11-2018
Time of Arrival: 9:30:00
Time of Departure: 10:11:00

Maintenance Details

Maintenance Description: Routine maintenance

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check tuning adjustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check and adjust car & cwt guide shoes	Y
Check all safety switches, limits in lift well	Y
check brake operation rope brake and associated equipment	Y
Check pit equipment and check water for pit	Y
Fire Service Operation Test	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

Service Technician

Kevin Wilkins

Customer Email

brighton@acebodycorp.com.au