

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:

88 Albert Road

88 Albert Road South Melbourne 3205

Contract No. P3613

Callouts ID: 22054

Date of Call: 22-10-2018 9:01:15 Time of Arrival: 22-10-2018 9:16:00 Rectification Time: 22-10-2018 9:21:00 Time of Departure: 22-10-2018 9:39:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): 1

Call Description: person stuck in lift

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Power Failure

Work Action (CORRECTION): See Work description

Work Description: Lifts reported SWP \r\nNo power to lifts, power restored tested lift both running as normal\r\nChargeable

Part Required: No Parts Required

Service Technician Report Customer

Dwain Sanderson Ben 0413 166 058