



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

EE Gunn Reserve Pavilion
0 Malane St Caulfield
Contract No: P3399

Maintenance:

Date of Call: 27-11-2018
Time of Arrival: 15:00:00
Time of Departure: 15:45:00

Maintenance Details

Maintenance Description: Routine maintenance.

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Test all car safties	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check tuning ajustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check and ajust car & cwt guide shoes	Y
Check all safety switches, limits in lift well	Y
Check pit equipment and check water for pit	Y
Check trailer flexes, attachments running clearance	Y
Check hydrolic tank oil level, valves RAM etc	Y
Test Emergency Light Unit	Y
Test Lift Communications	Y

Service Technician

Kevin Wilkins

Customer Email

DHipsher@gleneira.vic.gov.au