



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Laverton

Metro Laverton Station Laverton

Contract No: P3587

Callouts: 22200

Date of Call: 05-11-2018 15:51:18

Time of Arrival: 05-11-2018 16:15:00

Rectification Time: 05-11-2018 16:40:00

Time of Departure: 05-11-2018 16:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Closed

For Lift(s): Lift 4

For Floor(s): 1

Call Description: Lift door on top level out of track

Order Number: 02AA60762

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Rhs landing door out of door track\nsuspect been hit or kicked out\nRe align and re fit door shoes\nTest operation

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer