

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
The Royal Albert
15 Queens Road Melbourne
Contract No: P3577

Callouts: 22590

Date of Call: 13-12-2018 14:42:24 Time of Arrival: 13-12-2018 15:10:00 Rectification Time: 13-12-2018 16:10:00 Time of Departure: 13-12-2018 16:15:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 2
For Floor(s): 1

Call Description: SWP

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Car doors not fully closing due to obstruction in car door tracks, \r\nlift was been used by removalists moving furniture,\r\ncleared obstructio tracks checked operation ok.

Part Required: No Parts Required

Service Technician Report Customer

Robert Pelle 0431772344