



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Shepparton Law Court
18 High Street Shepparton
Contract No: W3652

Callouts:

Date of Call: 19-12-2018 8:30:00
Time of Arrival: 19-12-2018 8:30:00
Rectification Time: 19-12-2018 9:30:00
Time of Departure: 19-12-2018 9:45:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): B

Call Description: Lift stuck ok B

Order Number: Nil

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Lift ooo on B. Found multiple door lock faults on the same floor. \r\nCheck and adjust door beak and latching mechanism. \r\nFound broken on CGS, re-terminate and test operation. Ok.

Part Required: No Parts Required

Service Technician

James Grey

Report Customer

Dean Patterson