



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Maribyrnong City Council - Municipal Offices (61 Napier St, Footscray)
61 Napier St Footscray
Contract No: 3395

Callouts: 22191

Date of Call: 05-11-2018 10:16:04
Time of Arrival: 05-11-2018 10:30:00
Rectification Time: 05-11-2018 15:35:00
Time of Departure: 05-11-2018 3:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): g

Call Description: SWP

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Passenger out on arrival\r\nLift below bottom bottom level\r\nDuring testing lift faulting more frequently losing position and stopping at terminal floors\r\nLift shut down

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer