



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Waltham St 9, Sandringham
9 Waltham St Sandringham
Contract No: P3260

Callouts: 22633

Date of Call: 17-12-2018 10:06:00
Time of Arrival: 17-12-2018 13:45:00
Rectification Time: 17-12-2018 13:45:00
Time of Departure: 17-12-2018 14:07:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Noisy

For Lift(s): 1

For Floor(s): G

Call Description: noise while traveling

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Running On Arrival

Work Action (CORRECTION): See Work description

Work Description: Ran lift inside car for 20 mins, no noise found. Checked door operator from on top of the lift, ran lift top to bottom on inspection, no noise found.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

.