



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

The Clayton Hotel
319 Clayton Road Clayton
Contract No: B3738

Callouts:

Date of Call: 11-11-2018 15:19:00
Time of Arrival: 11-11-2018 16:15:00
Rectification Time: 11-11-2018 16:15:00
Time of Departure: 11-11-2018 16:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): g

Call Description: Swp

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Passengers out approximately 350pm with assistance from mfb on site\r\nMfb shut down power to lift to open the doors of lift\r\nIn doing so clearing the fault as once power turned on lift returned to normal service\r\nTested thoroughly no fault found

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer