

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Collins St 15, Melbourne
15 Collins St Melbourne
Contract No: P3334

Callouts ID:

Date of Call: 16-10-2018 16:49:00 Time of Arrival: 16-10-2018 17:05:00 Rectification Time: 16-10-2018 18:01:00 Time of Departure: 16-10-2018 18:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): gnd

Call Description: OOO Doors open gnd floor

Order Number: 1

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Damaged light rays managed to do a temporairy repair will have to order new ones

Part Required: Light rays

Service Technician Report Customer

Phil Dodsworth yes