



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Bowen Cres 3, Melbourne
3 Bowen Cres Melbourne
Contract No: P3031

Callouts: 22573

Date of Call: 12-12-2018 12:14:46
Time of Arrival: 12-12-2018 16:00:00
Rectification Time: 12-12-2018 16:20:00
Time of Departure: 12-12-2018 16:35:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 3

For Floor(s): g

Call Description: lift is out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): Reset Control System

Work Description: Drive fault reset ran and tested

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

.