



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Woodlands Golf Club
109 White Street Mordialloc
Contract No: B3593

Callouts:

Date of Call: 03-12-2018 8:50:00
Time of Arrival: 03-12-2018 9:30:00
Rectification Time: 03-12-2018 10:30:00
Time of Departure: 03-12-2018 10:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 1,2

For Floor(s): 1

Call Description: Lift ooo doors open

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Doors open reported to have broken down Saturday.\r\nOperator not closing doors/timed out.\r\nReset and ran potential user error, manager v confirm staff are using lift correctly. Also found dirty contact on close curcuit. Cleaned contact and will order new relay.

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0