



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Nicholas Building
37 Swanston St Melbourne
Contract No: 3265

Callouts: 22257

Date of Call: 12-11-2018 11:23:01
Time of Arrival: 12-11-2018 12:45:00
Rectification Time: 12-11-2018 13:20:00
Time of Departure: 12-11-2018 14:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 2

For Floor(s): 3

Call Description: stuck on lv 3 with doors open

Order Number: ?

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Adjust Doors/Locks

Work Description: Doors out of mesh, repositioned doors and checked door operation G-10th floors

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

Izzi Golding - 0434 869538