



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Ashdowne Apartments
237 Flinders Lane Melbourne
Contract No: 3508

Callouts: 22410

Date of Call: 27-11-2018 9:50:00
Time of Arrival: 27-11-2018 11:30:00
Rectification Time: 27-11-2018 12:40:00
Time of Departure: 27-11-2018 12:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 6

Call Description: screws on outer door has fallen off. Door is jammed again.

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): Replace Door/Lock Component

Work Description: Replaced faulty fixing bolt on 6th floor landing door closer

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

Vickie 0415 336 332