



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Werribee Mansion (Sofitel Hotel & Spa)
0 K Rd Werribee
Contract No: P3088

Callouts:

Date of Call: 27-11-2018 8:00:00
Time of Arrival: 27-11-2018 8:00:00
Rectification Time: 27-11-2018 8:30:00
Time of Departure: 27-11-2018 8:50:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 1

For Floor(s): 3

Call Description: Shut down from last night due to broken car door bridging piece

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Replace Door/Lock Component

Work Description: Car door lock bridging piece had snapped
Replaced with new and test operation

Part Required: 1x formator car door bridging piece

Service Technician

Matt Grieger

Report Customer