



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Box Hill
Metro Box Hill Station Box Hill
Contract No: P3581

Callouts ID: 22085

Date of Call: 24-10-2018 8:40:30
Time of Arrival: 24-10-2018 9:20:00
Rectification Time: 24-10-2018 11:00:00
Time of Departure: 24-10-2018 11:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): Escalator 1

For Floor(s): 0

Call Description: down escalator stopped working

Order Number: 656848

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Lower left and rail entry pushed in, found blutack on hand rail and clean up entry point as well to ensure safe cleanance without tripping.

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0