



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Beth Rivkah Primary Wing
14-20 Balaclava Road East St Kilda
Contract No: B3376

Callouts: 22607

Date of Call: 14-12-2018 13:22:04
Time of Arrival: 14-12-2018 14:10:00
Rectification Time: 14-12-2018 14:20:00
Time of Departure: 14-12-2018 14:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): BRPW

For Floor(s): B

Call Description: lift out of order

Order Number: .

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Found lift on B with tight guide shoe on R/H landing door. Remove and reseal. Test - ok.

Part Required: No Parts Required

Service Technician

Kevin Wilkins

Report Customer

Adrianna 9522 8222