



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Hoddle St 253, Collingwood
253 Hoddle St Collingwood
Contract No: P3434

Callouts: 22669

Date of Call: 19-12-2018 16:37:50
Time of Arrival: 19-12-2018 16:58:00
Rectification Time: 19-12-2018 16:10:00
Time of Departure: 19-12-2018 16:20:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 2

For Floor(s): G

Call Description: out of order with doors open on ground floor

Order Number: 16273

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): Reset Control System

Work Description: Error code 54. Reset and checked locks ran and tested

Part Required: No Parts Required

Service Technician

Brad Stellini

Report Customer

Melissa