



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
03 9687 9099
info@unitedlifts.com.au

Customer Details:

Mekong Keilor East Vietnamese Aged Care
8 Trott Place Keilor East
Contract No: P3770

Maintenance:

Date of Call: 04-12-2018
Time of Arrival: 8:40:00
Time of Departure: 9:30:00

Maintenance Details

Maintenance Description: Routine maintenance. Reprogram and test lift phone. Clean car top and check equipment.

Maintenance Task	1
Contact Building Rep. Check Ride & Appointments.	Y
Clean & Check all M/R Equipment	Y
Clean out controller ad check operation of various parts.	Y
Check tuning adjustments	Y
Check car door operator and associated equipment.	Y
Clean & check landing door equipment	Y
Check car top safeties, Ropes, Inductors Lubricate Rails Etc.	Y
Check pit equipment and check water for pit	Y
Clean lift well equipment	Y
Check hydrolic tank oil level, valves RAM etc	Y
Test Lift Communications	Y

Service Technician

mat tehan

Customer Email

tracey.bui@mvacaus.com