



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

La Trobe St 171, Melbourne
171 La Trobe St Melbourne
Contract No: P3391

Callouts: 22416

Date of Call: 27-11-2018 14:18:07
Time of Arrival: 27-11-2018 14:00:00
Rectification Time: 27-11-2018 14:30:00
Time of Departure: 27-11-2018 14:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): 10

Call Description: lift is out of order on level 10

Order Number: 2738165

DESCRIPTION OF WORK

Fault Found (CAUSE): Overload Tripped

Work Action (CORRECTION): Reset Control System

Work Description: PC1 c/b tripped reset and checked operation no fault found

Part Required: No Parts Required

Service Technician

Graeme Gathercole

Report Customer

.