

Unit 3 / 260 Hyde St YARRAVILLE VIC 3013 1300161740 info@unitedlifts.com.au

Service Address:
Hoddle St 253, Collingwood
253 Hoddle St Collingwood
Contract No: P3434

Callouts:

Date of Call: 06-12-2018 21:10:00 Time of Arrival: 07-12-2018 3:25:00 Rectification Time: 07-12-2018 3:35:00 Time of Departure: 07-12-2018 3:55:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): g

Call Description: Ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Error Log Fault

Work Action (CORRECTION): See Work description

Work Description: Error 38 brake switch error\r\nCheck that switches are making and breaking \r\nMonitor operation all ok

Part Required: No Parts Required

Service Technician

Report Customer

Matt Grieger