



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

1-3 Railway Place
1-3 Railway Place Cremorne
Contract No: 3572

Callouts:

Date of Call: 14-12-2018 23:42:00
Time of Arrival: 14-12-2018 23:55:00
Rectification Time: 15-12-2018 0:20:00
Time of Departure: 15-12-2018 0:40:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): S.W.P

For Lift(s): 1

For Floor(s): g

Call Description: Swp

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Lock Faulty

Work Action (CORRECTION): Replace Door/Lock Component

Work Description: Release passenger\r\nFound broken car gate contact\r\nReplace with new\r\nAlso ground floor foyer in front of lift flooded water possibly go down onto basement level locks

Part Required: Eshine car door lock

Service Technician

Matt Grieger

Report Customer