



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

metro Blackburn
metro Blackburn Blackburn
Contract No: W3655

Callouts:

Date of Call: 15-12-2018 13:11:00
Time of Arrival: 15-12-2018 13:25:00
Rectification Time: 15-12-2018 14:00:00
Time of Departure: 15-12-2018 14:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 2

For Floor(s): G

Call Description: lift 000 on G, Doors open

Order Number: 659643

DESCRIPTION OF WORK

Fault Found (CAUSE): Main Circuit Braker Tripped

Work Action (CORRECTION): See Work description

Work Description: ARD circuit breaker tripped. Found water on ARD, shutdown.

Part Required: No Parts Required

Service Technician

James Grey

Report Customer

Metro