



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Riggall St 61**

61 Riggall Street Broadmeadows

Contract No: P3608

**Callouts ID: 22084**

Date of Call: 24-10-2018 10:00:00

Time of Arrival: 24-10-2018 11:20:00

Rectification Time: 24-10-2018 11:50:00

Time of Departure: 24-10-2018 12:15:00

#### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** Doors Open

**For Lift(s):** 1

**For Floor(s):** 2

**Call Description:** big lift doors on the 2nd floor doors not opening properly & closing very slowly and alarm going off.

**Order Number:** .

#### DESCRIPTION OF WORK

**Fault Found (CAUSE):** Door Lock Faulty

**Work Action (CORRECTION):** Adjust Doors/Locks

**Work Description:** Clean down lv 2 door tracks and rollers. Adjust door guides and locks.

**Part Required:** No Parts Required

**Service Technician**

mat tehan

**Report Customer**

.