



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Brunswick St 150, Fitzroy
150 Brunswick St Fitzroy
Contract No: P3511

Callouts: 22330

Date of Call: 19-11-2018 10:52:59
Time of Arrival: 19-11-2018 11:15:00
Rectification Time: 19-11-2018 11:50:00
Time of Departure: 19-11-2018 12:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Button/Indicator Not Working

For Lift(s): 1

For Floor(s): 7

Call Description: level 7 button not working

Order Number: 007076

DESCRIPTION OF WORK

Fault Found (CAUSE): Button Smashed

Work Action (CORRECTION): See Work description

Work Description: Lv 7 button broken. Replace.

Part Required: No Parts Required

Service Technician

mat tehan

Report Customer

.