



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Kingsgate Hotel
131 King St Melbourne
Contract No: P3249

Callouts: 22428

Date of Call: 28-11-2018 15:57:04
Time of Arrival: 28-11-2018 16:52:00
Rectification Time: 28-11-2018 17:20:00
Time of Departure: 28-11-2018 17:33:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): 2

For Floor(s): Gnd

Call Description: lift is out of order, pushed level to go to all panel light not working. doors open

Order Number: *

DESCRIPTION OF WORK

Fault Found (CAUSE): Door Operator Fault

Work Action (CORRECTION): Reset Door Operator

Work Description: Doors couldnt close, found door operator fault. Reset operator, returned to service. Cleaned door tracks.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

emily 0396294171