



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Palm Avenue 26
26 Palm Avenue Reservoir
Contract No: 3659

Callouts: 22688

Date of Call: 21-12-2018 13:46:15
Time of Arrival: 21-12-2018 14:20:00
Rectification Time: 21-12-2018 15:00:00
Time of Departure: 21-12-2018 15:10:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Doors Open

For Lift(s): 2

For Floor(s): 2

Call Description: stuck with doors open

Order Number: 16310

DESCRIPTION OF WORK

Fault Found (CAUSE): Faulty Contactor

Work Action (CORRECTION): Replace/Repair Reply or Contactor

Work Description: Contactor sticking. Repair and test lift.

Part Required: No Parts Required

Service Technician

mat tehan

Report Customer

Holly JACOBS GROUP