



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013  
1300161740  
info@unitedlifts.com.au

Service Address:

**Tarneit Railway**  
0 Cnr Leakes Rd & Derrumitt Rd Tarneit  
Contract No: 3610

## Callouts ID:

Date of Call: 15-10-2018 18:41:00  
Time of Arrival: 15-10-2018 19:30:00  
Rectification Time: 15-10-2018 19:55:00  
Time of Departure: 15-10-2018 20:10:00

### CALLOUTS DETAILS

**Reported Fault (COMPLAINT):** O.O.O

**For Lift(s):** 1

**For Floor(s):** G

**Call Description:** Lift making loud noise

**Order Number:**

### DESCRIPTION OF WORK

**Fault Found (CAUSE):** See Work Description

**Work Action (CORRECTION):** See Work description

**Work Description:** Lift break make noise when picking up and dropping, needs adjustment in service. Spoke to area supervisor he will attend later this week.

**Part Required:** No Parts Required

**Service Technician**

Daniel Barry

**Report Customer**

..