



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Metro Box Hill
Metro Box Hill Station Box Hill
Contract No: P3581

Callouts ID:

Date of Call: 22-10-2018 14:30:00
Time of Arrival: 22-10-2018 15:00:00
Rectification Time: 22-10-2018 15:27:00
Time of Departure: 22-10-2018 15:27:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): Lift 1

For Floor(s): 1

Call Description: Lift car door *rhs, knocked off track by McDonalds delivery contractor.\r\nContractor managed to get door back on track. Guide required bend and re tightening.\r\nReturned lift to service

Order Number: 0

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: .

Part Required: No Parts Required

Service Technician

Zane Tregurtha

Report Customer

0