



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

18-20 Regent ST
18-20 Regent St Richmond
Contract No: W3727

Callouts: 22634

Date of Call: 17-12-2018 8:57:00
Time of Arrival: 17-12-2018 9:20:00
Rectification Time: 17-12-2018 10:30:00
Time of Departure: 17-12-2018 10:30:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): O.O.O

For Lift(s): Lift 1 - Builders Lift

For Floor(s): G

Call Description: out of order

Order Number: *

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): See Work description

Work Description: Door tracks had been distorted, pinching door guides, suspect heavy weight building materials transported through lift. Straightened track, returned to service.

Part Required: No Parts Required

Service Technician

Nathan Downton

Report Customer

David Spierings