



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

Hoddle St 253, Collingwood
253 Hoddle St Collingwood
Contract No: P3434

Callouts: 22685

Date of Call: 21-12-2018 10:35:09
Time of Arrival: 21-12-2018 10:15:00
Rectification Time: 21-12-2018 10:57:00
Time of Departure: 21-12-2018 10:59:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): Playing Up

For Lift(s): 2

For Floor(s): g

Call Description: lift is working intermittently - does not respond sometimes.

Order Number: 16305

DESCRIPTION OF WORK

Fault Found (CAUSE): Obstruction in doors

Work Action (CORRECTION): See Work description

Work Description: Electrical cord wedged in foors disabling closure causing error

Part Required: No Parts Required

Service Technician

Marek Torrico

Report Customer

#