



Unit 3 / 260 Hyde St YARRAVILLE VIC 3013
1300161740
info@unitedlifts.com.au

Service Address:

King St 27, Melbourne
27 King St Melbourne
Contract No: P3304

Callouts:

Date of Call: 06-11-2018 14:11:00
Time of Arrival: 06-11-2018 14:45:00
Rectification Time: 06-11-2018 15:00:00
Time of Departure: 06-11-2018 15:00:00

CALLOUTS DETAILS

Reported Fault (COMPLAINT): See Fault Description

For Lift(s): 1

For Floor(s): g

Call Description: Water in lift shaft and saying ooo

Order Number:

DESCRIPTION OF WORK

Fault Found (CAUSE): See Work Description

Work Action (CORRECTION): See Work description

Work Description: Water entered lift shaft from roof\r\nWhole car top covered in water and all in lift shaft \r\nCar door operators, light ray units, elu, car top box, inspection box, locks, pit etc all covered in water\r\nShut.down

Part Required: No Parts Required

Service Technician

Matt Grieger

Report Customer